

BILANS POWIETRZA									
Nr	Nazwa pomieszczenia	Pow. (m2)	Wys. Pom (m)	Kubatura (m3)	Krotność w/h	N1	W1	WC2	Uwagi
1.01	pom. gospodarcze	1,93	3,10	5,98	8,4		50		
1.02	gabinet lekarski	7,00	3,10	21,70	2,8	60	60		
1.03	gabinet lekarski	10,20	3,10	31,62	2,2	70	70		
1.04	gabinet lekarski	14,28	3,10	44,27	2,0	90	90		
1.05	gabinet lekarski	12,30	3,10	38,13	2,1	80	80		
1.06	gabinet lekarski	13,20	3,10	40,92	2,2	90	90		
1.07	sekretariat	11,00	3,10	34,10	2,1	70	70		
1.08	klatka schodowa	17,48	3,10	54,19	-				Istn. wentylacja
1.09	wc personelu	5,78	2,50	14,45	3,5			50	
1.10	wc pacjentów	3,82	2,50	9,55	5,2			50	
1.11	wc pacjentów	3,82	2,50	9,55	5,2			50	
1.12	wc pacjentów nps	7,73	2,50	19,33	2,6			50	
1.13	korytarz	132,2	3,10	409,82	2,3	930	680		
1.14	klatka schodowa	24,33	3,10	75,42	-				Istn. wentylacja
1.15	gabinet lekarski	15,87	3,10	49,20	2,0	100	100		
1.16	gabinet lekarski	14,19	3,10	43,99	2,0	90	90		
1.17	gabinet lekarski	13,76	3,10	42,66	2,1	90	90		
1.18	gabinet lekarski	14,92	3,10	46,25	2,1	95	95		
1.19	gabinet diagnostyczno zabiegowy	16,42	3,10	50,90	3,3	170	170		
1.20	poczekalnia	27,1	3,10	84,01	-				Uwzględnione w bilansie korytarza
1.21	gabinet lekarski	13,65	3,10	42,32	2,1	90	90		
1.22	gabinet lekarski	13,54	3,10	41,97	2,1	90	90		
1.23	gabinet lekarski	13,54	3,10	41,97	2,1	90	90		
1.24	gabinet lekarski	13,54	3,10	41,97	2,1	90	90		
1.25	gabinet lekarski	13,54	3,10	41,97	2,1	90	90		
1.26	gabinet lekarski	13,54	3,10	41,97	2,1	90	90		
1.27	gabinet lekarski	13,54	3,10	41,97	2,1	90	90		
1.28	gabinet lekarski	13,35	3,10	41,39	2,2	90	90		
1.29	gabinet lekarski	12,72	3,10	39,43	2,0	80	80		