

Wyniki - Grzejniki pod'ogowe

Numer Pion	Dzia³.	Pom.	Typ grz.	Fc [m2]	Lc [m]	B [m]	Tf [°C]	Fb [m2]	Lb [m]	Bb [m]	Tfb [°C]	Qobl [W]	Qwym [W]	dn [mm]	w [m/s]	dp [Pa]	tz [°C]	dt [K]	AG	G [kg/s]
		P1	GP-TERAKOTA	19.3	64.2	0.300	34.61					975	925	18	0.15	2170	49.44	10.10	1.00	0.02329
		P1	GP-TERAKOTA	19.1	63.7	0.300	34.65					975	925	18	0.15	2155	49.56	10.09	1.00	0.02329
		P1	GP-TERAKOTA	17.9	59.5	0.300	34.64					910	863	18	0.14	1636	49.54	10.09	1.00	0.02174
		P1	GP-TERAKOTA	23.4	78.1	0.300	34.62					1170	1110	18	0.18	3893	49.52	10.23	1.00	0.02795
		P1	GP-TERAKOTA	18.5	61.7	0.300	34.61					910	863	18	0.14	1689	49.54	10.36	1.00	0.02174
		P1	GP-TERAKOTA	15.0	50.0	0.300	34.62					780	740	18	0.12	831	49.32	9.84	1.00	0.01863
		P4	GP-TERAKOTA	15.3	50.9	0.300	33.24					900	842	18	0.14	1352	49.33	9.86	1.00	0.02150
		P5	GP-TERAKOTA	12.9	42.9	0.300	33.27					770	716	18	0.12	691	49.41	9.79	1.00	0.01839
		P5	GP-TERAKOTA	13.1	43.7	0.300	33.19					770	716	18	0.12	699	49.13	9.80	1.00	0.01839
		P1	GP-TERAKOTA2	15.0	50.0	0.300	34.63					780	740	18	0.12	833	49.47	9.94	1.00	0.01863