

Wyniki - Grzejniki podłogowe

Numer	Pom.	Typ grz.	Fc	Lc	B	Tf	Fb	Lb	Bb	Tfb	Qobl	Qwym	dn	w	dP	tz	dt	AG	G
Dział.			[m <sup>2</sup> ]	[m]	[m]	[°C]	[m <sup>2</sup> ]	[m]	[m]	[°C]	[W]	[W]	[mm]	[m/s]	[Pa]	[°C]	[K]		[kg/s]
Pion																			
	P1	GP-TERAKOTA	20.0	80.0	0.250	35.16					1170	1113	18	0.18	4002	49.50	9.83	1.00	0.02795
	P1	GP-TERAKOTA	20.0	80.0	0.250	35.19					1170	1113	18	0.18	4001	49.61	9.89	1.00	0.02795
	P1	GP-TERAKOTA	20.0	80.0	0.250	35.19					1170	1113	18	0.18	4001	49.61	9.89	1.00	0.02795
	P1	GP-TERAKOTA	20.0	80.0	0.250	35.16					1170	1113	18	0.18	4002	49.50	9.83	1.00	0.02795
	P1	GP-TERAKOTA	16.0	64.0	0.250	35.13					910	866	18	0.14	1764	49.52	10.05	1.00	0.02174
	P1	GP-TERAKOTA	17.0	68.6	0.350	32.80					900	856	18	0.14	1290	49.46	10.01	1.00	0.02150
	P3	GP-TERAKOTA	12.8	36.5	0.350	32.92					770	651	18	0.12	591	49.39	9.02	1.00	0.01839
	P3	GP-TERAKOTA	15.0	42.9	0.350	32.17					770	651	18	0.12	661	46.62	8.88	1.00	0.01839
	P1	GP-TERAKOTA2	16.0	64.0	0.250	35.07					910	866	18	0.14	1760	49.39	10.01	1.00	0.02174