

Wyniki - Pomieszczenia

Symbol	ti [°C]	Qo [W]	Qzc [W]	Qdef [W]	Qgrz [W]	Agrz
O1	20	0	0	0	0	0.000
P1	30	6500	335	0	6166	0.948
	GP-TERAKOTA grzejnik pod'ogowy					721 0.947
	GP-TERAKOTA2 grzejnik pod'ogowy					722 0.947
	GP-TERAKOTA grzejnik pod'ogowy					886 0.950
	GP-TERAKOTA grzejnik pod'ogowy					1125 0.949
	GP-TERAKOTA grzejnik pod'ogowy					863 0.948
	GP-TERAKOTA grzejnik pod'ogowy					925 0.948
	GP-TERAKOTA grzejnik pod'ogowy					925 0.948
P4	28	900	58	0	842	0.936
	GP-TERAKOTA grzejnik pod'ogowy					842 0.936
P5	28	1540	109	0	1431	0.929
	GP-TERAKOTA grzejnik pod'ogowy					715 0.929
	GP-TERAKOTA grzejnik pod'ogowy					715 0.929