



Condition	
Cooling	
Indoor DB	24,0 °C
Humidity	50 %
Indoor WB	17,1 °C
Outdoor DB	32,0 °C
Heating	
Indoor DB	20,0 °C
Outdoor DB	-20,0 °C
Humidity	100 %
Outdoor WB	-19,9 °C