



1:1 000

P124/057308 - zasilenie obvodu
moe 12.5kW zab. 3x25A

Budova linii kablovej ze smpa tot. leni 242V olt. 190m
(pnej. YAKXS 4x120mm², P2-Rs/LZV/LZR(F))

28.08.2024
Technik ds. Prizkaze
Sebastian Pose

Os-0029 TR-100kVA
Obw 01 52-51 3x100A
AsXS 4x70mm² 270m