








REV 1	M8 earthing terminal has been revised.	01/07/2011
REV 2		
REV 3		




**INFORMATION**



Secondary Terminals M5




A-DETAIL  
SCALE 3:1



NOTE: All dimensions are in mm.  
 Secondary terminals are at P1 (at P2 according to request).  
 Small deviations in dimensions and construction possible.

TIGHTENING TORQUE (Nm)	Min.	Max.
M5 (Secondary Terminal)	2.5	3.5
M8 (Ground Terminal)	15	20
M12 (Primary Terminal)	60	70

UNIT	PARTNAME	ITEM	MTRL.DIMEN.	MTRL.COD.	DRAWING NO.	CAST RESIN MTRL.TYPE
REV.	DRW.BY	DATE	NAME	SIGNATURE		
TOLERANCE	CONTROL	DATE	NAME	SIGNATURE		
DIN 7168-g	PREPARED BY		CHECK BY			
SCALE	ATB 20-BS CURRENT TRANSFORMER				RAW.MTRL.CODE	ALT SAC 3935
					SEMI FINISHED MTRL.	
					5383-00	